

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 58367
 Rec.
 Well No.
 Permit No.
Do not fill in

No. of Arden Road

Owner ERNEST M. HAUSWURZ Driller JOHN FRIEWALT

Address 105 BONNIEVILLE AVE Address 105 BONNIEVILLE AVE Lic. No. 9

Location of well: 13 1/2 SR 1/4 SW 1/4 N 13 1/4
1/4 1/4 Sec. 8, T. 22 N/S, R. 41 E, in Clark County - L.A. Hwy. County

Water will be used for DOMESTIC Total depth of well 173 FT.

Size of drilled hole 8" Weight of casing per linear foot 10 GA.

Thickness of casing 10 GA. Temp. of water

Diameter and length of casing 8" 40 FT.
 (Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface 112 FT.

If flowing well describe control works
 (Type and size of valve, etc.)

Date of commencement of well August 20, 1953 Date of completion of well OCT. 28, 1953

Type of well rig STAR

LOG OF FORMATIONS				Water-bearing Formation, Casing Perforations, Etc.
From feet	To feet	Thickness feet	Type of material	
0	7	7	7 FT. SOIL.	
7	65	58	FROM 7' to 65' HARD PAN	Chief aquifer (water-bearing formation) from <u>150</u> to <u>165</u> ft.
65	120	55	" 65' to 120' CONGLOMERATED	Other aquifers <u>120 - 124</u>
120	124	4	" 120' to 124' BROKEN UP	
124	150	26	" 124' to 150' BROWN LIMIE	
150	165	15	" 150' to 165' LIMIE + GRAVEL	
165	173	8	" 165' to 173' HARD CLAY.	First water at <u>120</u> feet.
				Casing perforated from <u> </u> to <u> </u> ft.
				Size of perforations <u> </u>

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material
			<p>The diagram shows a vertical well casing with a plug at the top. To the right, a vertical line is marked with '15' and '11'. Below this, a diagonal line is labeled 'radius 2000'.</p>

CASING RECORD

Diam. casing	From feet	To feet	Length	Remarks—Seals, Grouting, Etc.
8"			40'	<p>CROUTING 1 1/2 YARDS. 12' RISE OF WATER AFTER COMPLETION 112' STANDING WATER FROM SURFACE, FIRST SEEPAGE OF WATER, 120'</p>

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLERS STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed John F. Stewart
Well Driller

By.....

License No. 9

Dated Oct. 28, 1953

(Not to be filled in by Driller)

not in use - no pump installed.