LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8 in.	0	180	180	first 65 ft. of well was drilled slightly larger than 12 in. in diameter remainder of well is 12 in. diameter well was gravel packed from bottom up to 65 ft. of top, well is concreted from 0 ft. to 65 ft. down. There was a very little water at the first strata on 5 trip down with the bailer and the well was dry the 2nd. strata had an abundance of water

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailing test indicates 800 gal. per hr. water is cool

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed McKesson & Stock
Well Driller

By Earl McKesson

License No. 200

Dated May 21, 19 55

(Not to be filled in by Driller)