

**WELL LOG AND REPORT TO THE STATE ENGINEER
OF NEVADA**

LWD

Log No. 58462
 Rec. _____ 19____
 Well No. _____
 Permit No. _____
 Do not fill in.

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Owner Myrtle Sellman + Duke Sexton Driller Douglas Slagle

Address 1334 Eastwood Dr. Las Vegas Address 4518 E. Vegas Vally Dr. No. 137

Location of well: SW $\frac{1}{4}$ SW $\frac{1}{4}$ Sec 34, T20 N/S, R 62 E, in Clark County
 or Beesley & East Charleston Bld

Water will be used for Domestic Total depth of well 150 ft.

Size of drilled hole 12 in. Weight of casing per linear foot 16.90 lb. 12.15 lb.

Thickness of casing 188 and 10 gauge Temp. of water cool

Diameter and length of casing 8 5/8" X 150 ft.
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure _____

If nonflowing well give depth of standing water from surface 51 Ft.

If flowing well describe control works _____
(Type and size of valve, etc.)

Date of commencement of well Dec. 15. 1966 Date of completion of well Dec. 24th. 1966

Type of well rig Buckrus Erie, Series Two ---22W

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	40	40	Dark brown silt
*40	43	3	Rock
*43	45	2	Gravel and Water
45	70	25	White clay and sand
*70	75	5	Gravel, sand and Water
75	93	18	White clay
*93	98	5	Gravel and Water
*98	125	27	Series of Water, clay and sand
125	138	13	White clay and sand
*138	144	6	Gravel, sand and Water
144	150	6	Light brown clay

Water-bearing Formation, Casing Perforations, etc.

93 to 98 ft.

Chief aquifer (water-bearing formation)

from 43 to 45 ft.

Other aquifers 70 to 75

138 to 144

98 ft. to 125 ft.

First water at 43 ft. feet.


Casing perforated

from 50 to 150 ft.

Size of perforations

1/8" X 12"

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material
			

CASING RECORD

Diam. casing	From feet	To feet	Length	REMARKS—Seals, Grouting, etc.
8 5/8	0	150	150	From 0 to 10ft the casing is 8 5/8" Diam X 10 gauge From 10 ft.to 150 ft.casing is 10 8 5/8 " Diam. X .188 wall Cemented from 0 to 50 ft. 0 to 50 ft. from 50 to 150 ft.is gravel packed

GENERAL INFORMATION—Pumping Test, Quality of Water, etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed *Douglas Slagle*
 By *Douglas Slagle*
 Douglas Slagle
 License No. 137

Dated Dec 29, 1966

(Not to be filled in by Driller)
