WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58561
Permit No.
Basin 129

NOTICE OF INTENT NO. 34391

1. OWNER Frank McCusky
MAILING ADDRESS P.O. Box 567
Winnemucca, NV 89446

ADDRESS AT WELL LOCATION
None Designated, Unionville, NV

2. LOCATION NE 1/4 NE 1/4 Sec. 27 T 30N N/S R 34E E Pershing County
PERMIT NO. _____ Issued by Water Resources | 11-180-14 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gravel & Boulder		0	45	45
White & Green Rock		45	50	195
White, green & Black Roack		50	145	95
See next line		145	220	75
Greenish Gray Rock Medium hard				
White & Reddish Rock	xx	220	245	25

RECEIVED OCT 21 1996 PM 2:09 STATE ENGINEER'S OFFICE

Date started 9/16/96, 19__
Date completed 9/20/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 245 Feet Depth Cased 245 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	60	Feet
8	Inches	60	Feet	245	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	14.96	.188	0	60
6 5/8	12.92	.188	0	245

Perforations:
Type perforation mill cut
Size perforation 1/8
From 205 feet to 245 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 245 feet

9. WATER LEVEL
Static water level 33 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
By driller performing actual drilling on-site or contractor

Date 10-14-96