WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58565
Permit No.
Basin 089

NOTICE OF INTENT NO. 31945

1. OWNER JIM GRIEL
MAILING ADDRESS 5375 EAST LAKE BLVD
CARSON CITY NV 89704

ADDRESS AT WELL LOCATION
5375 EAST LAKE BLVD
CARSON CITY NV 89704

2. LOCATION NE ¼ NE ¼ Sec. 17 T 16 N/S R 20 E WASHOE County
PERMIT NO. W-438 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY AND SAND		0	10	10
SANDS		10	117	107
HARD SAND		117	158	41
LOOSE SAND		158	195	37
SAND AND BOULDERS		195	197	2
SAND AND CLAY MIX		197	211	14
SAND AND CLAY		211	216	5
ROCK		216	217	1

Date started MAY 01, 19 96
Date completed JUNE 28, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
600	22.42	24

8. WELL CONSTRUCTION
Depth Drilled 217 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
20 Inches		0 Feet	210 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	33.38	.250	+ 2	100
12	33.38	.250	150	180
12	33.38	.250	200	210

Perforations:
Type perforation JOHNSON WIRE WRAP
Size perforation 100 SLOT
From 100 feet to 150 feet
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 210 feet

9. WATER LEVEL
Static water level 28.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION COMPANY (Contractor)
Address 9955 NORTH VIRGINIA STREET (Contractor)
RENO NEVADA 89506
Nevada contractor's license number issued by the State Contractor's Board 0021246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1593
Signed [signature] (By driller performing actual drilling on site or contractor)
Date JUNE 28, 1996

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627