

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22974

1. OWNER Chris & Beth Swartz ADDRESS AT WELL LOCATION N/A  
 MAILING ADDRESS Hc 76 Box 999  
Tonopah N.V. 89049 NONE

2. LOCATION N.W. 1/4 N.W. 1/4 Sec 32 T. 5 N/S R. 55 E. NYE County  
 PERMIT NO. N/A 113-61-01 NONE  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	
Sand gravel		2	4	
Cemented gravel		4	10	
Sandy clay		10	15	
Cemented gravel		15	19	
Sandy Clay		19	20	
gravel		20	21	
Cemented gravel		21	56	
Sandy Clay-tan		56	66	
Sand	water	66	78	
gravel	water	78	79	
Sand		79	87	
gravel	water	87	88	
Sand		88	94	
gravel	water	94	95	
Sand		95	105	
gravel	water	105	106	
Sand		106	109	
gravel	water	109	110	

8. WELL CONSTRUCTION  
 Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10</u> Inches	<u>0</u> Feet	<u>5.0</u> Feet
<u>8</u> Inches	<u>5.0</u> Feet	<u>7.8</u> Feet
<u>6</u> Inches	<u>7.8</u> Feet	<u>11.0</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.5</u>	<u>12.9</u>	<u>.188</u>	<u>-1</u>	<u>110</u>

Perforations:  
 Type perforation mill  
 Size perforation 1/2 x 2.5 x 6 Row

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 90 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 65 feet

9. WATER LEVEL  
 Static water level 51 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 66 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NATHAN R. MAYNARD  
 Contractor

Address P.O. Box 174 Lund N.V. 89317  
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0022869  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Nathan Maynard  
 By driller performing actual drilling on site or contractor  
 Date July 2 - 96

Date started May 7 1996  
 Date completed June 7 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50</u>	<u>6'</u>	<u>3 hrs</u>