WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58569
Permit No.
Basin 183

NOTICE OF INTENT NO. 21023

1. OWNER DeeAnn Holt
MAILING ADDRESS Enterprise, Ut. 84725
ADDRESS AT WELL LOCATION Lake Valley, NV.

2. LOCATION NE ¼ SW ¼ Sec. 10 T. 5 N/S R. 66 E. Lincoln County
PERMIT NO. 59114 (Issued by Water Resources) Parcel No. — Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☑ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☑ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, gravel		463	470	7
40% Clay, Sand, gravel		470	507	37
Cemented-Sand, gravel		507	521	14
40% Clay-Sand-gravel		521	533	12
Sand-gravel		533	561	28
50% Clay-Sand-gravel		561	570	9
Clay		570	583	13
Sand-gravel		583	644	61
Clay		644	649	5
Sand-gravel		649	674	25
Clay		674	680	6
40% Clay-Sand-gravel		680	696	16
30% Clay-Sand-gravel		696	711	15
Sand-gravel		711	760	49

Date started 4-8, 1996
Date completed 4-16-, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 760 Feet Depth Cased 760 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
15 Inches		463 Feet	760 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"		.250	463	760

Perforations:
Type perforation Mill
Size perforation 5/16 x 2.5
From 433 feet to 760 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☑ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Drilling (Contractor)
Address Box 18 New Castle, Ut. 84756 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0031759
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1710
Signed Dale L. Gardner (By driller performing actual drilling on site or contractor)
Date 4-19-96