DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 58574
Permit No.
Basin 212

RECEIVED
OCT 2 1970
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

1. OWNER Mr. Pierre Busa ADDRESS 2563 E. Reno Street
Las Vegas, Nevada

2. LOCATION S.E. ¼ S.E. ¼ Sec. 9 T. 22 South ~~N/S~~ R. 61 E. Clark County
PERMIT NO. Domestic Well, for home

3. TYPE OF WORK
New Well XX Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic XX Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable XX Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface Fill		0	½	½
Calache		½	6	5½
Very Hard Calache		6	12	6
White Clay		12	20	8
Red Clay		20	25	5
Hard Wh. Clay & Gravel		25	60	35
Very Hard Rock		60	70	10
Red Clay & Graval		70	84	14
& Hard Rock		84	86	2
*****Water Graval & Sand	6	86	92	6
Brown Sticky Red Clay		92	100	8
Light Brn, Clay		100	107	7
Cream Colored Clay		107	112	5
Solid Hard Rock		112	115	3
Light Brown Clay		115	135	20
****Sand, Gravel & Water	6	135	141	6
Brown Clay		141	155	14
Sheet Rock		155	157	2
Light Brn, Clay		157	165	8
Hard Brn. Rock & Graval		165	205	40
****Graval, Clay & Water	10	205	215	10
Cemented Graval		215	250	35
Hard Cream Colored Clay		250	257	7
Cemented Graval		257	280	23
****Gravaly Sand, Water	5	280	285	5
Cemented Graval		285	300	15

Date started October 9, 1970
Date completed October ~~XX~~ ~~XXX~~ 22nd., 1970

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	37	136	30 Min Baleing

BAILER TEST
G.P.M. 37 Draw down 51 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 14 inches Total depth 300 feet
Casing record
Weight per foot 12.16 # Thickness 10 Ga.

Diameter	From	To
8 Inch	0'	300'
inches	feet	feet
(8 inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes XX No ☐ Type Cement Grout
Depth of seal 50 feet
Gravel packed: Yes XX No ☐
Gravel packed from 50' feet to 300 feet

Perforations:
Type perforation Cutting Torch
Size perforation 1/8" x 12"--1 each Foot
From 80 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 85 Feet below land surface
Flow none G.P.M.
Water temperature 83 ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DOUGLAS SLAGLE
Address 4518 E. Vegas Valley Drive
Las Vegas, Nevada
Nevada contractor's license number 3325
Nevada driller's license number 137
Signed Douglas Slagle
Date October 22nd. 1970

USE ADDITIONAL SHEETS IF NECESSARY

5471