LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8 5/8OD	0	180	180	Cemented from 0 to 50 feet 2 yards of cement Graveled packed from 50 to 175 feet 4 yards of pea gravel

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

1HP Submersible Pump, 4DL18, 168' 1½" riser pipe, 220 Tank.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Drill & Pump Serv.
Well Driller

By C. F. Effinger

License No. 212

Dated December 24, 1962

(Not to be filled in by Driller)