LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8¼	0	60	60	Cemented with 1 yd. cement and sand ready mix.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Standing water level 75 ft. from surface.
Bailed hole 30 minutes with bailer.
Lowered water level 12 feet.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed John H Barnett
Well Driller

By.....

License No. 185

Dated December 12, 19 54

(Not to be filled in by Driller)