LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material
163	171	8	Series of WATER, Sand,Clay an Gravel
171	175	4	Lt. Brn. Clay
Depth of Well			

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8 In.	0	175	175	Used 2 kinds of Casing, 75 Ft. of 8 Gage an 100 Ft. .277 Wall due to Supplier was out of 10 or 8 Gage 0' to 100' is.277 Wall an 100' to 175' is 8 Gage Well is Gravel packed from 175' to 59'. Casing is Cemented in for 59 Ft., Useing 2 3/4 Yds. of 6 sk. Redy-Mix Grout

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

A bailing test indicates that this Well, will deliever Approx. 1500 GPH. pulling from a 120 Ft8 level

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Donald Sloff
Well Driller

By Self

License No. 137

Dated Feb., 18, 19 55

(Not to be filled in by Driller)