LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"	0	200	201'	First 50 feet cemt. grouted. Steel plate welded on top of casing.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

10 GPM. approx bail test.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed McGarvie Plumbing & Welding
Well Driller

By Don P. McGarvie

License No. 132

Dated 2/16/55, 19

(Not to be filled in by Driller)