LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"	0	200	200	gravel packed from 55 ft to 200 grouted from 55 ft to 0 - W.M.K. 6 sack mix of pea gravel well grout 3 yds used

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Static Water level is 84 ft - Bailed 460 gal - in 20 minutes - drawed down to 117 ft recovered to 89 ft in 20 minutes

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Douglas Sleagle
Well Driller

By Self

License No. 137

Dated July 29, 1961

(Not to be filled in by Driller)