LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8" O.D.	0	40	40	8" cemented down to 35 ft with one yd. concrete

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

bailed 20 G.P.M. from 100 ft.

WELL DRILLERS STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed S. R. McTurney
Well Driller

By.....

License No. 45

Dated 4-13, 1953

(Not to be filled in by Driller)