LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"	0	162	162	Casing is 1 ft above ground - cemented to a depth of 50 ft. - 1½ of cement.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailer Test 20 gallons a min -pulls down to 110 feet

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed J E Howard
Well Driller

By Nolan Howard

License No. 134

Dated Jan. 15, 19 55

(Not to be filled in by Driller)