

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"OD	0	170	170	Cemented from 0 to 50 feet 3 yards of cement Graveled packed from 50 to 170 feet 4 yards of pea gravel

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Drill. & Pump Serv.
Well Driller

By A. F. Effinger
License No. 212

Dated December 4, 1957

(Not to be filled in by Driller)
