LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"	0'	200'	200'	12 ga., 50 feet cemented w/1/2 Yd. cement grout ready mixed

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailing test 20 gpm at 150' pumping level

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Nevada Pump & Supply Co.
Well Driller

By [signature]

License No. 133

Dated Jan. 5, 19 55

(Not to be filled in by Driller)