LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"	1 foot above surface	150	151	Back filled outside of casing to 53 feet with pea gravel cemented from surface to 53 feet with 2 yards ready mix grout.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailed hole at 20 gallons per minute for 45 minutes 12 foot draw down.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed John H Barnett
Well Driller

By.....

License No. 185

Dated September 15, 1956, 19..

(Not to be filled in by Driller)