DIVISION OF WATER RESOURCES

Deepening Job

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 58707
Permit No.
Basin 212

1. OWNER Antonette Peter ADDRESS 236 Mesa Verde

2. LOCATION N/W ¼ S/E ¼ Sec. 9 T. 22 N/S R. 61 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well XXXXXXXXXXXXX Recondition ☐
Deepen XX Other ☐

4. PROPOSED USE
Domestic XX Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable XX Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Red Clay | | 127 | 141 | 14 |
| Light brown sandy clay | | 141 | 170 | 29 |
| Red clay, sandy | | 170 | 184 | 14 |
| Rock | | 184 | 188 | 4 |
| Water & pea gravel | X | 188 | 190 | 2 |
| Sandy brown clay | | 190 | 206 | 16 |
| Hard rock | | 206 | 214 | 8 |
| Clay pea gravel & sand | | 214 | 220 | 6 |
| Fractured rock & water | X | 220 | 300 | 80 |

(Well was 127 ft and 50 ft of casing when I started)
"Slagle"

RECEIVED
APR 5 1974
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started March 18, 1974
Date completed March 24, 1974

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 37 Draw down 63 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION 255
Diameter hole ~~12¼x6~~ inches Total depth 300 feet
Casing record
Weight per foot Thickness

| Diameter | From | To |
|---|---|---|
| 6 inches | 45 feet | 300 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Torch
Size perforation 1/8 X 12"
From 80 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 91 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Douglas Slagle
Address 4518 E Vegas Valley Dr.
Nevada contractor's license number 3325
Nevada driller's license number 137
Signed Douglas Slagle
Date April 4 1974

USE ADDITIONAL SHEETS IF NECESSARY

5471