


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY

Log No. **58727**

Permit No. \_\_\_\_\_

Basin **16a**



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **15132**

1. OWNER **OXBORROW, JERRY**  
 MAILING ADDRESS **4140 E PAWNEE PAHRUMP, NV 89041**

ADDRESS AT WELL LOCATION **4140 E PAWNEE**

2. LOCATION **NW 1/4 SW 1/4 Sec. 20 T 21S** N/S **R 54E** E **NYE** County \_\_\_\_\_  
 PERMIT NO. **45-312-06** **GREEN SADDLE RANCH**

Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & CALICHIE		0	60	60
CALICHIE	WB	60	73	13
CLAY		73	92	19
CALICHIE	WB	92	104	12
CLAY		104	122	18
CALICHIE	WB	122	138	16
CLAY		138	150	12
CALICHIE	WB	150	163	13
CLAY		163	175	12

8. WELL CONSTRUCTION  
 Depth Drilled **175** Feet Depth Cased **175** Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
**12.25** Inches **0** Feet **175** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>8.625</b>	<b>16.94</b>	<b>.188</b>	<b>0</b>	<b>175</b>

Perforations:  
 Type perforation **FACTORY SAW CUT**  
 Size perforation **1/8 X3**

From **135** feet to **155** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50** \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **175** feet

9. WATER LEVEL  
 Static water level **58** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Great Basin Drilling Co.** Contractor  
 Address **PO BOX 4220** Contractor  
**PAHRUMP, NV 89041**

Nevada contractor's license number issued by the State Contractor's Board **30880**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**

Signed *Thomas Du*  
 By driller performing actual drilling on-site or contractor  
 Date **10/17/96**

Date started **10/14/96**, 19\_\_\_\_  
 Date completed **10/17/96**, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

