LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8 3/8 inches I.D.	0	175 Ft.	175 Ft.	0 ft. to 60 ft. is not Perforated 60 ft. to 175 ft. is Perforated First 60 ft. of Casing is Cemented in, useing a 6 Sack mixture, of Redy-Mix Grout

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

A bailing Test indicates that well should deliever aprox. 1800 gph. pulling fron a 90 Ft. level.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Douglas Sleight
Well Driller

By Self

License No. 137

Dated Dec 12, 1954

(Not to be filled in by Driller)