LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
6" OD	0	160	160	Gravel packed to 51 ft from surface, cemented in using 2½ yrds of 6 sack ready-mix grout.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailing test indicates this well will deliver approx. 1000 gal. per hour.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed [illegible] Well Driller

By [illegible]

License No. 137

Dated 4-8-55, 19

(Not to be filled in by Driller)