LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
6"	0	154'	154'	50 feet cement grout 102 feet pea gravel fill

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

20 gpm at 95 feet pumping level

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed NEVADA PUMP & SUPPLY COMPANY
Well Driller

By Thos DeBruyn Jr

License No. 133

Dated June 10, 1955, 19

(Not to be filled in by Driller)