LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"	0	165	165	Casing extends 1 foot above ground - cemented to a depth of 50 ft. 1½ yards cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailer Test - 25 gal per minute - pulls down to 75 ft.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed J. E. Howard
Well Driller

By

License No. 134

Dated Mar. 24, 19 55

(Not to be filled in by Driller)