

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

OFFICE
 STATE ENGINEER
 AUG 13 1955

CASING RECORD

Diam. casing	From feet	To feet	Length	Remarks—Seals, Grouting, Etc.
8 inch	0	200	200	50 feet cement seal Bailed down 30 feet water standing at 30 feet Cannot lower the water level at 20 gallon per minute.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed: *William P. Moore*
 Well Driller

By:

License No. 195

Dated August 13th, 1955

(Not to be filled in by Driller)
