LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"	0	200	200	Cemented from 0 to 50 feet Gravel packed from 50 to 200 feet

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Water is Warm --Installed a 1½ H.P. submergible Pump, static water was 110 Ft. & pumping Approx. 25 G.P.M. at 20# 40# Pressure, well draws-down to 124 Ft. (GOOD)

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Douglas Slagle
Well Driller

By Douglas Slagle

Douglas Slagle 137
License No.

Dated May 31, 1967

(Not to be filled in by Driller)

10/16/2012 by DSB