DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 58851
Permit No.
Basin 212

1. OWNER Ronald Wooldridge ADDRESS Box 443 Henderson Nevada

2. LOCATION SW¼ ¼ NE¼ ¼ Sec. 9 T. 22 S N/S R. 61 E. Clark County
PERMIT NO. 330 FT So of El Dorado on West Side of Placid Street

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gypsum Rock		0	18	18
Red Clay		18	21	3
Gravel & Red Clay		21	27	6
Red Clay		27	30	3
Hard Rock		30	36	6
Gypsum Clay		36	41	5
Lt Brown Clay		41	46	5
Hard Rock		46	50	4
Lt Brown Clay		50	62	12
Red Sticky Clay		62	66	4
Sandy Red Clay		66	85	19
Hard Lt Brn Clay		85	90	5
Hard Red Clay		90	94	4
Hard Rock		94	96	2
Water Clay & Gravel	X	96	98	2
Clay & Gravel		98	105	7
Lt Brn Clay		105	117	12
Red Clay		117	128	11
Hard Lt Brn Clay		128	142	14
Hard Rock		142	144	2
Red Clay		144	195	51
Cemented Gravel		195	203	8
Water & Gravel	X	203	206	3
Hard Lt Brn Clay & gravel		206	268	62
Sand, Gravel & Water	X	268	271	3
Sticky Red Clay & Rocks		271	300	29

Date started April 7 1977, 19
Date completed April 22 1977, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
APR 27 1977
Div. of Water Resources
Branch Office — Las Vegas, Nev.

BAILER TEST
G.P.M. 30 Draw down 15 feet 5 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 300 feet
Casing record
Weight per foot 12.6# Thickness 10 gage

Diameter	From	To
8 5/8 inches	0 - 2 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 52 ft feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 52 feet to 300 feet

Perforations:
Type perforation Torch
Size perforation 1/8 x 12"
From feet to feet
From 90 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 92 Feet below land surface
Flow G.P.M.
Water temperature Warm ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Douglas Slagle
Address 6350 L.V. Blvd So - LV Nev
Nevada contractor's license number 3325
Nevada driller's license number 137
Signed Douglas Slagle
Date April 26 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471