

OFFICE USE ONLY  
 Log No. 58852  
 Permit No. \_\_\_\_\_  
 Basin 092B

I

NOTICE OF INTENT NO. 30642

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340.

1. OWNER NAZIR ANSARI ADDRESS AT WELL LOCATION 2720 Cactus View  
 MAILING ADDRESS 25 Cassas Crt. Reno, Nevada 89506  
Reno, Nevada 89511

2. LOCATION SE 1/4 NW 1/4 Sec 10 T 20N N/S R 19 E Washoe County  
 PERMIT NO. 088-040-13 Golden Valley Subdivision Name

Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Decomposed Granite		1	30	29
Green hard granite		30	70	40
Fracture	X	70	71	1
Green hard granite		71	79	8
Gray hard granite		79	82	3
Fracture	X	82	83	1
Gray hard granite		83	99	16
Fracture granite	X	99	105	6
Gray hard granite		105	120	15
Fracture	X	120	121	1
Gray hard granite		121	125	4

NOTE: Water appears milky, may clear up with development with pump.

8. WELL CONSTRUCTION  
 Depth Drilled 125 Feet Depth Cascd 125 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 125 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	125

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 80 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50 feet  
 Placement Method:  Pumped  Poured  
 Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 125 feet

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 20 P.S.I.  
 Water temperature cold °F Quality Milky, might clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date August 9, 1996

Date started 8-6-96 19\_\_\_\_\_  
 Date completed 8-7-96 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		

