DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 58894
Permit No.
Basin

1. OWNER Orville Stange ADDRESS 3464 Saddle

2. LOCATION S/W ¼ S/W ¼ Sec. 18 T. 21 XX/S R. 62 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well XX Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic X Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable X Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soft Clay		0	15	15
White Clay		15	31	16
Gravel & Water	X	31	33	2
Red clay		33	75	42
Pea gravel & water	X	75	77	2
Brown clay		77	125	48
Red caly		125	143	18
Water	X	148	146	3
Red clay		146	180	34
Water	X	180	182	2
Brown clay		182	200	18

RECEIVED
APR 5 1974
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started Jan. 9. 1971, 19
Date completed Jan. 16. 1971, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 50 Draw down 40 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12" inches Total depth 200 feet
Casing record
Weight per foot 16.15 Thickness logage

Diameter	From	To
8 5/8 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes X No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes X No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation Torch
Size perforation 1/8 X 12"
From 50 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 24 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Douglas Slagle
Address 4518 E. Vegas Valley Dr.
Nevada contractor's license number 3325
Nevada driller's license number 137
Signed Douglas Slagle
Date Feb 15 1971

USE ADDITIONAL SHEETS IF NECESSARY

5471

I