DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 58904
Permit No.
Basin

1. OWNER Phil Abbott ADDRESS 2842 Stanley, N.L.V.

2. LOCATION SW ¼ NW ¼ Sec. 19 T. 21 ~~N~~/S R. 62 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand		0	3	3
decomposed caliche		3	6	3
good caliche		6	10	4
white clay		10	14	4
clay w/limestone ledges		14	22	8
clay		22	48	26
clay w/hard ledges		48	116	68
sandy clay		116	187	71
clay		187	200	13
sandy clay w/gravel lenses		200	240	40
sand w/sandy clay lenses		240	300	60

Date started July 2, 1968, 19
Date completed July 8, 1968, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 300 feet
Casing record 8 5/8
Weight per foot 11.44# Thickness 10 ga.

Diameter	From	To
8 5/8 inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement 1 yd.
Depth of seal 65' feet
Gravel packed: Yes ☒ No ☐ 4 yds.
Gravel packed from 65 feet to 300 feet

Perforations:
Type perforation Torch cut
Size perforation 1/8 x 6"
From 200 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 37 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Drilling and Pumps, Inc.
Address 3521 Spring Mtn. Rd., L.V.
Nevada contractor's license number 6294A
Nevada driller's license number 532
Signed M. D. Briner
Date July 29, 1968

USE ADDITIONAL SHEETS IF NECESSARY

5471