



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28051

1. OWNER William C. Giles ADDRESS AT WELL LOCATION 21 E. Arden Wy  
Yerington NV. 8  
 MAILING ADDRESS 21 E. Arden Wy  
Yerington NV.  
 2. LOCATION SW 1/4 SE 29 T. 14 N. S. R. 25 E. Lyon County  
 PERMIT NO. 14-271-63 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden Sand		0	3	3
Soft Blow Sands		3	20	17
Coarse Sands & Gravels		20	63	43
Gravels	X	63	87	24
Brown Clay & Sandy		87	128	41
Coarse Gravels	XXXX	128	150	22

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 1/4 Inches To 0 Feet 150 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>150</u>

Perforations:  
 Type perforation Mill slot  
 Size perforation 3 X 3/32  
 From 130 feet to 150 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 63  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 63 feet to 150 feet

9. WATER LEVEL  
 Static water level 35 feet below land surface  
 Artesian flow G.P.M. 35+ P.S.I.  
 Water temperature Cold °F Quality Good

Date started 8-29 1996  
 Date completed 8-1 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>35+</u>	<u>30</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A. H. Pump Company Contractor  
 Address 5551 Hwy 50 E #3 Contractor  
Carson City NV. 89701  
 Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael J. Beck  
 By driller performing actual drilling on site or contractor  
 Date 8-1-96

RECEIVED  
 95 AUG - 2 PM 10:47  
 STATE ENGINEERS OFFICE