

OFFICE USE ONLY
 Log No. 58915
 Permit No. 108
 Basin 108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28051

1. OWNER William C. Giles ADDRESS AT WELL LOCATION 21 E. Arden Way
 MAILING ADDRESS Yerington NV. 8
 2. LOCATION SW 1/4 S60 1/4 Sec. 29 T. 14 N. R. 25 E. Lyon County
 PERMIT NO. 14-271-63 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden Sand		0	3	3
Soft Blow Sands		3	20	17
Coarse Sands & Gravels		20	63	43
Gravels	X	63	87	24
Brown Clay-Sandy		87	128	41
Coarse Gravels	XXX	128	150	22

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10/4 Inches To 150 Feet
 Inches Feet
 Inches Feet
 Inches Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>150</u>

Perforations:
 Type perforation Mill slot
 Size perforation 3x7/32
 From 130 feet to 150 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 63 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 63 feet to 150 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. 35 P.S.I.
 Water temperature Cold °F Quality Good

Date started 8-29, 1996
 Date completed 8-1, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>35</u>	<u>30</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge,
 Name A. H. Pump Company Contractor
 Address 5551 Hwy 50 E #3 Carson City NV. 89701
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael J. Heck
 By driller performing actual drilling on site or contractor
 Date 8-1-96