

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31565

1. OWNER Byron Wholey ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 11637 Osage Rd 11637 Osage Road  
Reno, Nevada 89506 Reno, Nevada 89560  
 2. LOCATION SE 1/4 SE 1/4 Sec 13 T 21N N/S R 18 East Washoe County  
 PERMIT NO. 086-25-039 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G. Brown		0	20	
Brown Clay		20	35	
Multi Colored Volcanic Rock & Brown Clay		35	120	
Multi Colored Volcanic Rock & Gray Clay		120	160	
Multi Colored Course Sand		160	195	
Multi Colored Gravels		195	282	
T.D. 282				

8. WELL CONSTRUCTION  
 Depth Drilled 282 Feet Depth Cased 282 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10-5/8 Inches 0 Feet 70 Feet  
8-1/2 Inches 70 Feet 282 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6-5/8</u>	<u>13.92</u>	<u>-188</u>	<u>1-1/2</u>	<u>282</u>

Perforations:  
 Type perforation Factory Sawn  
 Size perforation 3/32" X 3  
 From 242 feet to 262 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 282 feet to 50 feet

9. WATER LEVEL  
 Static water level 170 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

Date started March 27, 1996  
 Date completed April 1, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>12</u>		<u>8 Hours</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service, Inc  
 Contractor  
 Address 1800 1/2 Frazer Avenue  
 Contractor  
Sparks, Nevada 89431  
 Nevada contractor's license number 35387-A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1509T-1  
 Division of Water Resources, the on-site driller  
 Signed Randy Welch  
 By driller performing actual drilling on site or contractor  
 Date April 2, 1996