4

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58928
Permit No.
Basin 105

NOTICE OF INTENT NO. 23179

1. OWNER RICK EATON CONST.
MAILING ADDRESS GARDNERVILLE, NV
ADDRESS AT WELL LOCATION 1733 SUNSET
GARDNERVILLE

2. LOCATION SW ¼ SE ¼ Sec. 35 T. 13 N/S R. 20 E. DOUGLAS County
PERMIT NO. — Issued by Water Resources
23-560-03 Parcel No.
WILDFLOWER Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY/GRAVEL		0	8	8
CEMENTED GRAVEL		8	12	4
SAND GRAVEL		12	25	13
SANDY CLAY/GRAVEL		25	118	93
SAND/GRAVEL		118	138	20
SANDY CLAY		138	172	44
SAND/GRAVEL		172	177	5
SANDY CLAY		177	213	36
SAND GRAVEL	✓	213	229	16
SANDY CLAY		229	240	11

Date started C-4-96, 1996
Date completed 6-11-96, 1996

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	25+		2½

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
9 7/8 Inches		50 Feet	240 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	0	240

Perforations:
Type perforation FACTORY
Size perforation 3x3½
From 240 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 240 feet to 180 feet

9. WATER LEVEL
Static water level 85.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDCO EXPLORATION, INC. Contractor
Address 1780 CURRY RD. Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 21673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-11-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627