

OFFICE USE ONLY  
 Log No. 58930  
 Permit No. 1051  
 Basin. I  
 NOTICE OF INTENT NO. 28474

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER RICHARD DOUD ADDRESS AT WELL LOCATION 706 PAULA ST GARDNERVILLE  
 MAILING ADDRESS CARSON CITY, NV

2. LOCATION SW 1/4 NE 1/4 Sec. 24 T 12 N R 20 E DOUGLAS County  
 PERMIT NO. 29-452-22 Issued by Water Resources Parcel No. RUHENSTROTH Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY/GRAVEL		0	48	48
CEMENTED GRAVEL/PORE		48	54	6
SANDY CLAY		54	59	5
SAND GRAVEL		59	63	4
SANDY CLAY/GRAVEL		63	74	11
SANDY CLAY		74	105	31
CLAY		105	129	24
SAND GRAVEL		129	134	5
SANDY CLAY/GRAVEL		134	168	34
SAND/GRAVEL	✓	168	186	12
SANDY CLAY/GRAVEL		180	184	4
CEMENTED GRAVEL	✓	184	200	16

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
9 7/8 Inches 50 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>200</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 1/8 x 3  
 From 200 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 90 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 6-19-96 1996  
 Date completed 6-26-96 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDCO EXPLORATION, INC Contractor  
 Address 879 RITTER DR, GARDNERVILLE, NV 89410 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 27673A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 6-26-96