WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58932
Permit No.
Basin

NOTICE OF INTENT NO. 31648

1. OWNER John Cefalu
MAILING ADDRESS P.O. Box 33
Smith, NV. 89430

ADDRESS AT WELL LOCATION
245 Hudson Aurora Road
Smith, NV. 89430

2. LOCATION NW ¼ NW ¼ Sec. 3 T. 10 (N)/S R. 24 (E) Lyon County

PERMIT NO. (Issued by Water Resources) | 10-601-15 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	11	
Sm Grvls w Sand		11	32	
Coarse Sand W Grvls		32	60	
Brn Clay Some Grvls		60	125	
Grvls		125	180	
Small Grvls	WB	180	230	
Rocks w Some Sand	WB	230	240	

Date started 6/21/96, 19
Date completed 6/25/96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	140	3 1/2

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
9 7/8	0	240

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	240

Perforations:
Type perforation Factory
Size perforation 3/32
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 56 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Phil Brown / Smith Valley Drilling (Contractor)
Address 83 Hudson Aurora (Contractor)
Smith, NV. 89430
Nevada contractor's license number issued by the State Contractor's Board 41673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1949
Signed Phil Brown (By driller performing actual drilling on site or contractor)
Date 6/28/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627