

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24361

1. OWNER USGS/Washoe Co Utilities Dept ADDRESS AT WELL LOCATION LV #2
400 Paramount Ct, Reno
 MAILING ADDRESS 333 W. Nye Ln
Carson City, NV 89706
 2. LOCATION NE 1/4 SW 1/4 Sec 34 T. 21 N/S R. 19 E Washoe County
 PERMIT NO. M/C-1055 Issued by Water Resources Parcel No. 080-531-31 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy clay</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Clayey sand</u>	<u>X</u>	<u>5</u>	<u>7</u>	<u>2</u>
<u>sandy clay</u>	<u>*</u>	<u>7</u>	<u>8 1/2</u>	<u>1 1/2</u>
<u>clay</u>		<u>8 1/2</u>	<u>13</u>	<u>4 1/2</u>
<u>sandy clay</u>	<u>*</u>	<u>13</u>	<u>14</u>	<u>1</u>
<u>clayey sand</u>	<u>*</u>	<u>14</u>	<u>17</u>	<u>3</u>
<u>clay</u>		<u>17</u>	<u>19</u>	<u>2</u>
<u>clayey sand</u>	<u>*</u>	<u>19</u>	<u>24</u>	<u>5</u>

8. WELL CONSTRUCTION
 Depth Drilled 24 Feet Depth Cased 24 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 24 Feet
6 6 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>24</u>

Perforations:
 Type perforation slot
 Size perforation .010
 From 17 feet to 24 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 5 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 18 feet to 24 feet

9. WATER LEVEL
 Static water level 2.12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 6/16, 1996
 Date completed 6/16, 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Armando R. Robledo Contractor
 Address 90 USGS 333 W. Nye Ln Contractor
Carson City, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller FP1851
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6/16/96

LOC 58941

4918

ARKANSAS

27

BOUNDARY

CORPORATE

RENO

CORP

RENO NE, NEV.

NE/4 RENO 15' QUADRANGLE
N3937.5—W11945/7.5

1967
PHOTOREVISED 1982
DMA 2063 III NE—SERIES V896

