WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58946
Permit No.
Basin 212

NOTICE OF INTENT NO. 15315

1. OWNER JOHN McCABE
MAILING ADDRESS
ADDRESS AT WELL LOCATION 95 + KYLE CANYON Rd

2. LOCATION SW ¼ NE ¼ Sec. 1 T. 19 N/S R. 59 E. CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. 470-250-064 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL + ROCKS.		0	60	60
CMT GRAVEL		60	400	340
CMT GRAVEL W/		400	650	250
STRKS LIMESTONE				

8. WELL CONSTRUCTION
Depth Drilled 650 Feet Depth Cased 650 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	0 Feet	650 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 9/16	10.8	.188	+1	650

Perforations:
Type perforation FACTORY SAW
Size perforation 1/8 x 2 1/2
From 590 feet to 630 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 650 feet

9. WATER LEVEL
Static water level 460 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DESERT DRILLING (Contractor)
Address 6475 GARY AVE (Contractor)
LAS VEGAS, NV. 89139
Nevada contractor's license number issued by the State Contractor's Board 34274
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594
Signed Tyndall Cook (By driller performing actual drilling on site or contractor)
Date 12-27-96

Date started 12-17, 1996
Date completed 12-20, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627