


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 58948
 Permit No. 624241
 Basin 212



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 1-109

1. OWNER MH, Inc. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3 Shadow Creek Dr. Shadow Creek Golf Course
No. Las Vegas, NV 89031
 2. LOCATION NE 1/4 NE 1/4 Sec. 25 T 19 N/S R 61 E Clark County
 PERMIT NO. 62424T 124-25-501-004
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt & Gravels		0	60	60
Silt, Sandstone & Brown Clay		60	190	130
Red Sandy Clay		190	260	70
Red Sandy Clay with some gravels		260	470	210
Blue Clay		470	550	80
Brown Clay		550	1344	794
Well abandoned from with gravel cement grout		1344/1377	577	498
As per directions from Tom Gallagher				

8. WELL CONSTRUCTION
 Depth Drilled 1344 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)

From	To
30 Inches	0 Feet 50 Feet
22 Inches	50 Feet 1344 Feet
Inches	Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	63.41	.250	+1	50
16	52.36	.312	0	40
12 3/4	43.77	.330	40	480

Perforations:
 Type perforation Johnson Screen
 Size perforation .060

From 100 feet to 300 feet
 From 340 feet to 460 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 0 feet to 498 feet


9. WATER LEVEL
 Static water level 157 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thompson Drilling Co. Contractor
 Address 4185 W. Harmon Contractor
Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 4286A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1851

Signed Richard Thompson
 By driller performing actual drilling on site or contractor
 Date 12/19/96



Date started 10/10 1996
 Date completed 12/19/ 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200	96	72