

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **58957**
 Permit No. _____
 Basin **162**
 14971 (14971)
 NOTICE OF INTENT NO. 14950

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **Shawn & Inez Thayer** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **3580 S Shawnee** **3580 South Shawnee Avenue**
Pahrump, NV 89048

2. LOCATION **SW** 1/4 **SW** 1/4 Sec. **35** T **20S** N/S R **533** E **Nye** County
 PERMIT NO. **41-091-18** **Calvada Valley**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|-----------------------|--------------|------|-----|-----------|
| Brown Clay/Calichia | | 0 | 15 | 15 |
| Brown Clay/Calichia | | 15 | 32 | 17 |
| Brown Clay | | 32 | 50 | 18 |
| Brown Sandy Clay | | 50 | 71 | 21 |
| White Clay / Calichee | x | 71 | 90 | 19 |
| Calichee/Brown Clay | x | 90 | 108 | 18 |
| Brwon Sandy Clay | x | 108 | 124 | 16 |
| Brown Sandy Clay | x | 124 | 140 | 16 |

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 Inches **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| 8 | 17 | 188 | 0 | 140 |

Perforations:
 Type perforation **Torch**
 Size perforation **.25 x 6**
 From **100** feet to **140** feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **50** feet to **140** feet

9. WATER LEVEL
 Static water level **55** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cold** °F Quality **good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2025**
 Signed *Shawn Strickland*
 By driller performing actual drilling on-site or contractor
 Date **12-17-96**

Date started **11/21/96**, 19____
 Date completed **11/22/96**, 19____

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | 50 | n/a | .5 |

