WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

14/900

OFFICE USE ONLY
Log No.: 58981
Permit No. 55116
Basin 212

NOTICE OF INTENT NO. 20608

1. OWNER Frehner Construction
MAILING ADDRESS 124 W. Brooks
Las Vegas, NV 89030
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ SW ¼ Sec 13 T 23 N/S R 60 E Clark County
PERMIT NO. C-170 Permit 55116 400-350 59230-61720
Waiver Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Caliche & Clay		0	40	
S & G Clay		40	120	
S & G Clay Limestone		120	140	
Gray Limestone		140	200	
Dark Brown Clay		200	240	
White Rock		240	420	
White Rock Dolamite		420	560	
Fractured Gray Limestone		560	720	

Date started 8/30, 19 96
Date completed 9/13, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 720 Feet Depth Cased 720 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		65 Feet	720 Feet
12 1/4 Inches		0 Feet	65 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+1	720

Perforations:
Type perforation Torch Cut
Size perforation 3/16 x 8
From 563 feet to 714 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 65
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level Unknown feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling Co. (Contractor)
Address 4185 W. Harmon (Contractor)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 290
Signed Richard Thompson
By driller performing actual drilling on site or contractor
Date 10/2/96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627