EW-29

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 59051
Permit No.
Basin 061

NOTICE OF INTENT NO. 28580

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SE ¼ SE ¼ Sec. 19 T. 36 N S R ~~40.50~~ E EUREKA County
PERMIT NO. 61248 T (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic MINING ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAYS, SAND GRAVEL		0	425	425
CARLINE FORMATION				
GRAY LIMESTONE, FRACTURES		425	630	205
WITH CALCITE				
BLACK MUDSTONE, SOME		630	850	220
FRACTURES WITH CLAYS				
HARD LIMESTONE, SOME		850	1410	560
FRACTURES & CLAYS				

Date started NOVEMBER 5, 1995
Date completed NOVEMBER 15, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
110	59	36

8. WELL CONSTRUCTION
Depth Drilled 1410 Feet Depth Cased 1404 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
31 Inches	0 Feet	75 Feet	
19 Inches	75 Feet	1,410 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	94	.375	0	75
12	35.5	.250	+2	41

Perforations:
Type perforation LOUVERED SLOT
Size perforation 1/8
From 41 feet to 1404 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 75
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 1 feet to 1410 feet

9. WATER LEVEL
Static water level 475 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature 70 °F Quality FAIR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1800

Signed VICTORY HERNANDEZ Victor Hernandez
By driller performing actual drilling on site or contractor

Date JANUARY 4, 1996

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627