

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 59085
 Rec. _____ 19____
 Well No. _____
 Permit No. _____
Do not fill in

Owner W. H. ~~Wiers~~ MCK. PANDBLIS Driller Effinger Bros.
 Address 2307 Webster Street Address 212 Anderson Lane Lic. No. 105
 Location of well: 1/4 Sec. 1/4, T. N/S, R. E, in Clark County
 or N. 1/4 S. 1/4 E. Section 10 T21S R62E
 Water will be used for Domestic Total depth of well 240 feet
 Size of drilled hole 12 Inch Weight of casing per linear foot 12.06 lbs.
 Thickness of casing 10 Gauge Temp. of water _____
 Diameter and length of casing 8 5/8" OD 240 feet 6 5/8" OD 50 feet
 (Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)
 If flowing well give flow in c.f.s. or g.p.m. and pressure 15 GPM
 If nonflowing well give depth of standing water from surface _____
 If flowing well describe control works 3" Threaded Cap with 2" outlet
 (Type and size of valve, etc.)
 Date of commencement of well January 20, 1955 Date of completion of well January 26, 1955
 Type of well rig "71 Speed Star"

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material	Water-bearing Formation, Casing Perforations, Etc.
0	2	2	Sand	
2	27	25	Limestone	
27	33	6	Red Sandy Clay	
33	44	11	White Sand	Chief aquifer (water-bearing formation) from <u>222</u> to <u>238</u> ft.
44	53	9	Red Sticky Clay	Other aquifers <u>197-205</u>
53	73	20	Red Sand	
73	77	4	Limestone	
77	94	17	Red Sandy Clay	
94	105	11	Sandstone	
105	119	14	Red Sandy Clay	
119	129	10	Sandstone	
129	147	18	Red Sandy Clay	
147	159	12	Sandstone	
159	165	6	Red Sticky Clay	First water at <u>73</u> feet.
165	178	13	Sandstone	
178	197	19	Red Sticky Clay	
197	205	8	Gravel (Water)	Casing perforated from <u>80</u> to <u>200</u> ft.
205	222	17	Red Sticky Clay	
222	238	16	Gravel (Water)	Size of perforations <u>1/8" X 1/2"</u>
239	240	2	Red Sticky Clay	

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8 5/8" OD	0	201	201	Cemented from 0 to 80 feet Graveled packed from 80 to 201 feet 5 yards of pea gravel 2 yards of cement
6 5/8" OD		50	50	

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Bros.
Well Driller
By A. F. Effinger
License No. 105

Dated January 26, 1955

(Not to be filled-in by Driller)
