DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 59094
Permit No.
Basin 212

1. OWNER George J. Vandermark ADDRESS 3415 Garden Drive Las Vegas, Nev 89121

2. LOCATION S.W. ¼ N.E. ¼ Sec. 14 T. 22 N/S R. 61 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface Soil		0	4	4
Red Sandy clay		4	75	71
Brown Clay streaks of gravel	W	75	110	35
Loose Gravel	W	110	210	100

RECEIVED
MAY 16 1975
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started March 27, 19 75
Date completed April 15, 19 75

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 210 feet
Casing record 210' 8 5/8" O.D.
Weight per foot 12.20 lbs Thickness 10 Ga.

Diameter	From	To
8 5/8" O.D. inches	0 feet	210 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 210 feet

Perforations:
Type perforation torch
Size perforation 1/4" Wide 6" long
From 90 feet to 210 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 76' 8" Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Louis F. Evans
Address 3012 Carroll St. N. L.V.
Nevada contractor's license number 3046
Nevada driller's license number 690
Signed Louis F. Evans
Date 5/14/75

USE ADDITIONAL SHEETS IF NECESSARY

5471