



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30046

1. OWNER Curtis Schmidline ADDRESS AT WELL LOCATION 325 Miners road, Fallon, NV 89406  
 MAILING ADDRESS 325 Miners Road  
Fallon, NV 89406

2. LOCATION NE 1/4 NE 1/4 Sec. 1 T 18N N/S R 28E E Churchill County  
 PERMIT NO. 006-191-12 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	4	4
Brown Clay		4	17	13
Sand		17	24	7
Clay		24	33	9
Gray Sand		33	42	9
Black Clay		42	70	28
Gray Sand		70	78	8
Gray Clay		78	88	10
Sand	X	88	95	7

8. WELL CONSTRUCTION  
 Depth Drilled 95 Feet Depth Cased 95 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 95 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	95

Perforations:  
 Type perforation Mill Cut  
 Size perforation 1/8  
 From 92 feet to 95 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 80  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 80 feet to 95 feet

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454  
 Signed Norman Parsons  
 By driller performing actual drilling on-site or contractor  
 Date \_\_\_\_\_

Date started 9/26/96, 19\_\_\_\_  
 Date completed 9/26/96, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>		<u>1 hr.</u>