

OFFICE USE ONLY
 Log No. 59317
 Permit No. _____
 Basin. 087

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30965

1. OWNER LOLA LOLA ADDRESS AT WELL LOCATION S. 1320
 MAILING ADDRESS 555 VISTA BLVD
SPARKS NV
 2. LOCATION NW 1/4 SE 1/4 Sec 2 T 19 N R 20 E W 1/4 1106 County
 PERMIT NO. 96 Issued by Water Resources Parcel No. 97 27 17 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other AVG

6. MW # LITHOLOGIC LOG 2

Material	Water Strata	From	To	Thick-ness
<u>08-16-96</u>				
<u>I FOUND THE</u>				
<u>WELL TO BE IN</u>				
<u>GOOD CONDITION</u>	<u>15'</u>			
<u>I THEN DRILLED</u>				
<u>THE CASING OUT</u>				
<u>TO A DEPTH OF</u>				
<u>30</u>				
<u>I THEN PRESSURE</u>				
<u>GRADED THE</u>				
<u>SOLE FROM 30'-0'</u>				
<u>WITH NEAT CEMENT</u>				

8. WELL CONSTRUCTION
 Depth Drilled 30' Feet Depth Cased 30' Feet
 HOLE DIAMETER (BIT SIZE)
 From 8" Inches To 30' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>SCA 40</u>	<u>PVC</u>	<u>0</u>	<u>30</u>

Perforations:
 Type perforation FALTOP
 Size perforation 0.20
 From 10' feet to 30' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 30'
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 15' feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 64.0 °F Quality N/A

Date started 8-16, 1996
 Date completed 8-16, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andrew Reser EXPLORATION DRILLING Contractor
 Address 1635 BELLEVUE RD Contractor
RENO NV 89509
 Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 10/2/96