

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32692

1. OWNER Mckenzie Construction ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO 1209 650 bigelow way
Reno Nv 99504 sparked Nv
 2. LOCATION SW 1/4 NW 1/4 Sec 9 T 19 N 20 E Washoe County
 PERMIT NO. MO 1013 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HEA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphaltic concrete		0'	0.5'	0.5
Dark grey silty sand clayey sand		0.5'	7'	6.5
grey brown sandy gravel cobble		7'	12'	5
grey brown sandy gravel cobble		12'	22'	10
Brown clayey sandy gravel cobble		22'	27'	5
Brown clayey sandy gravel cobble		27'	30'	3

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 27 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 30
8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.37</u>		<u>sch 40</u>	<u>0</u>	<u>18</u>

Perforations:
 Type perforation SLOT
 Size perforation .020
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 18 feet to 27 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 15 Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 23.4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

#3 monitoring well (East)
 Date started 2.14, 1996
 Date completed 2.14, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA Drilling Inc Contractor
 Address 75 Lowers creek RD
Carson City Nv 89704 Contractor
 Nevada contractor's license number 13697A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1902
 Division of Water Resources, the on-site driller
 Signed John S. Reiser
 By driller performing actual drilling on site or contractor
 Date 11.11.96