WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 59478
Permit No.
Basin 092B

NOTICE OF INTENT NO. 51799

1. OWNER John Jensen
MAILING ADDRESS 345 E Dwight Lane
ADDRESS AT WELL LOCATION 345 E Dwight Lane

2. LOCATION NW ¼ SE ¼ Sec. 11 T. 20 N/S R. 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 088-173-09 (Parcel No.) Hollis Kelly Ranchl (Subdivision Name)

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE: [X] Cable [ ] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dry Clay		0	35	
Clay & Dry		35	90	
Clay		90	125	
Sandie Clay		125	135	
Rock & Clay		135	145	
Rock & Clay		145	168	
Rock		168	185	
Brown Sandie Clay		185	200	
Gray Dry		200	225	
Gray Clay & Dry		225	245	
Dry		245	300	
		300	320	

Date started June 28 1996
Date completed July 27 1996

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	250	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6" Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	235
			255	300

Perforations:
Type perforation Factory
Size perforation 6"
From 235 feet to 255 feet
From 300 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 20
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature 58 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name J M Drilling (Contractor)
Address 1859 Hymer Ave (Contractor)
Sparks, NV 89431
Nevada contractor's license number issued by the State Contractor's Board 41172
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 786
Signed Ray Higginbotham (By driller performing actual drilling on site or contractor)
Date Aug 7 96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627