WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 59479
Permit No.
Basin 092B

NOTICE OF INTENT NO. 30011

1. OWNER Tony Albiniano
MAILING ADDRESS
ADDRESS AT WELL LOCATION Seneca St. Horizon Hills

2. LOCATION NW ¼ NW ¼ Sec 16 T 20 N/S R 19 E/W Washoe County
PERMIT NO. 00 570 1 Issued by Washoe Co Water Resources
082-240-29 Parcel No.
Horizon Hills Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE: [X] Cable [ ] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil + Clay		0	30	
Clay + Boulders		30	85	
Boulders		85	98	
Clay + Boulders		98	110	
Clay + Boulders		110	145	
Clay + Boulders		145	175	
Clay + Boulders		175	300	
Clay + Boulders		300	345	
Clay + Boulders		345	375	
Clay + Boulders		375	305	
Clay + Boulders		305	340	
Clay + Boulders		340	350	
		350	375	
Broken Clay		375	380	
Clay + Rock				

Date started Aug 12 —, 1996
Date completed Aug 30 —, 1996

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	250	1 hr

8. WELL CONSTRUCTION
Depth Drilled 380 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/4 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	360

Perforations:
Type perforation Factory
Size perforation 18
From 360 feet to 380 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow 12 G.P.M. P.S.I.
Water temperature 56 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name J.M. Drilling - Bill Snider Contractor
Address 1859 Hymer Ave Sparks, Nv. Contractor
Nevada contractor's license number issued by the State Contractor's Board 41172
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 786
Signed Ray Higginbotham By driller performing actual drilling on site or contractor
Date Aug 30, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627