

OFFICE USE ONLY
 Log No. 5955A
 Permit No. _____
 Basin. 049
 NOTICE OF INTENT NO. 30899

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER SAFEWAY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS MIN. CITY HIGHWAY
ELKO, NV
 2. LOCATION S4 1/4 S4 1/4 Sec 15 T 34 N 55 E ELKO County
 PERMIT NO. ELKO W-2-9 1-133-05 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other ABAND

6. MW #5 LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ON 8-1-96 I</u>	<u>19'</u>			
<u>FOUND THE WELL</u>				
<u>IN GOOD CONDITION</u>				
<u>I THEN DRILLED THE</u>				
<u>DRASING OUT TO 30'</u>				
<u>I THEN PRESSURE</u>				
<u>GRAINED THE HOLE</u>				
<u>FROM 30' TO 0' WITH</u>				
<u>NEAT CEMENT GROUT</u>				

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 30' Feet
 HOLE DIAMETER (BIT SIZE)
 From 8" To 0"
0" Inches 0' Feet 30' Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>SCH 40</u>	<u>PVC</u>	<u>0'</u>	<u>30'</u>

Perforations:
 Type perforation FACTORY
 Size perforation 020
 From 15' feet to 30' feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 30' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

RECEIVED
 90001-9 P112104
 DIVISION OF WATER RESOURCES

Date started 8-1 1996
 Date completed 8-1 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

9. WATER LEVEL
 Static water level 19' feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ANDRESEN EXPLORATION DRILLING Contractor
 Address 1635 BELFORD RD Contractor
ZENO, NV 89509
 Nevada contractor's license number 34525
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1028
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8/20/96